



Missouri Department of Natural Resources

PUBLIC NOTICE

DRAFT MISSOURI STATE OPERATING PERMIT

DATE: September 15, 2006

In accordance with the state Clean Water Law, Chapter 644, RSMo, Clean Water Commission regulation 10 CSR 20-6.010, and the federal Clean Water Act, the applicants listed herein have applied for authorization to either discharge to waters of the state or to operate a no-discharge wastewater treatment facility. The proposed permits for these operations are consistent with applicable water quality standards, effluent standards and/or treatment requirements or suitable timetables to meet these requirements (see 10 CSR 20-7.015 and 7.031). All permits will be issued for a period of five years, unless noted otherwise in the Public Notice for that discharge.

On the basis of preliminary staff review and the application of applicable standards and regulations, the Missouri Department of Natural Resources (MDNR), as administrative agent for the Missouri Clean Water Commission, proposes to issue a permit(s) subject to certain effluent limitations, schedules, and special conditions. The proposed determinations are tentative pending public comment.

Persons wishing to comment on the proposed permit conditions are invited to submit them in writing to the Department of Natural Resources, St. Louis Regional Office, 7545 South Lindbergh, Suite 210, St. Louis, Missouri 63125, ATTN: Thomas M. Siegel, Chief, Permits and Engineering. Please include the permit number in all comment letters.

Comments should be confined to the issues relating to the proposed action and permit(s) and the effect on water quality. The MDNR may not consider as relevant comments or objections to a permit based on issues outside the authority of the Clean Water Commission, (see Curdt v. Mo. Clean Water Commission, 586 S.W.2d 58 Mo. App. 1979).

All comments must be postmarked by October 15, 2006 or received in our office by 5:00 p.m. on October 18, 2006. The requirement of a signed document makes it impossible to accept email comments for consideration at this time. Comments will be considered in the formulation of all final determinations regarding the applications. If response to this notice indicates significant public interest, a public meeting or hearing may be held after due notice for the purpose of receiving public comment on the proposed permit or determination. Public hearings and/or issuance of the permit will be conducted or processed according to 10 CSR 20-6.020.

Copies of all draft permits and other information including copies of applicable regulations are available for inspection and copying at, DNR's website, <http://www.dnr.mo.gov/env/wpp/wpcp-pn.htm>, or at the Department of Natural Resources, Water Protection Program, 205 Jefferson Street, P.O. Box 176, Jefferson City, Missouri 65102, between the hours of 8:00 a.m. and 5:00 p.m., Monday through Friday.

Public Notice Date: September 15, 2006

Permit Number: MO-0109177

St. Louis Regional Office


| FACILITY NAME AND ADDRESS | NAME AND ADDRESS OF OWNER |
|--|---|
| Beauty View Acres Sewer District Beauty View Drive, Gray Summit, Mo 63039 | Beauty View Acres Sewer District P.O. Box 245, Gray Summit, MO 63039 |
| RECEIVING STREAM & LEGAL DESCRIPTION | TYPE OF DISCHARGE |
| Tributary to Labadie Creek SE¼, NW¼, Sec 6, T43N, R2E | Domestic, Reissue |

N<R

STATE OF MISSOURI

DEPARTMENT OF NATURAL RESOURCES

MISSOURI CLEAN WATER COMMISSION



MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law, (Chapter 644 R.S. Mo. as amended, hereinafter, the Law), and the Federal Water Pollution Control Act (Public Law 92-500, 92nd Congress) as amended,

Permit No. MO - 0109177

Owner: Beauty View Acres Sewer District
Address: P.O. Box 245, Gray Summit, MO 63039

Continuing Authority: Same as above
Address: Same as above

Facility Name: Beauty View Acres Sewer District
Address: Beauty View Drive, Gray Summit, MO 63039

Legal Description: SE¼, NW¼, Sec6, T43N, R2E
Receiving Stream: Tributary to Labadie Creek (P)

First Classified Stream and ID: Tributary to Labadie Creek (P) (1694)
USGS Basin & Sub-watershed No.: Missouri River Mainstream – Hermann to St. Louis (10300200 – 130002)

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

FACILITY DESCRIPTION

Outfall #001 - Sewer District/ Sub-division - SIC # 4952

Design flow is 26,000 Gallons per Day
Actual flow is 6,000 Gallons per Day
Design population equivalent is 260 .
Design Sludge production is 4.1 dry tons/ year.
Actual Sludge production is 2.8 dry tons/ year.

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of the Law.

Effective Date

Doyle Childers, Director, Department of Natural Resources
Executive Secretary, Clean Water Commission

Expiration Date
MO 780-0041 (10-93)

Mike Struckhoff, Director, St. Louis Regional Office

| A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS | | | | PAGE NUMBER 2 of 3 | | |
|--|----------|----------------------------|----------------|---------------------------|-------------------------|------------------|
| | | | | PERMIT NUMBER MO- 0109177 | | |
| The permittee is authorized to discharge from outfall(s) with serial number(s) as specified in the application for this permit. The final effluent limitations shall become effective upon issuance and remain in effect until expiration of the permit. Such discharges shall be controlled, limited and monitored by the permittee as specified below: | | | | | | |
| OUTFALL NUMBER AND EFFLUENT PARAMETER(S) | UNITS | FINAL EFFLUENT LIMITATIONS | | | MONITORING REQUIREMENTS | |
| | | DAILY MAXIMUM | WEEKLY AVERAGE | MONTHLY AVERAGE | MEASUREMENT FREQUENCY | SAMPLE TYPE |
| <u>Outfall #001</u> | | | | | | |
| Flow | gals/day | * | | * | once/ month | 24 hour estimate |
| BOD ₅ ** | mg/L | | 65 | 45 | once/ quarter*** | Note 1 |
| Total Suspended Solids** | mg/L | | 110 | 70 | once/ quarter*** | Note 1 |
| Temperature | °C | * | | * | once/ quarter*** | grab |
| Ammonia as N (May 1 – Oct. 31) | mg/L | 3.7 | | 1.9 | once/ quarter*** | grab |
| Ammonia as N (Nov 1 – Apr. 30) | mg/L | 7.5 | | 3.7 | once/ quarter*** | grab |
| pH – Units **** | SU | 6-9 | | 6-9 | once/ quarter*** | grab |
| MONITORING REPORTS SHALL BE SUBMITTED <u>QUARTERLY</u> ; THE FIRST REPORT IS DUE _____. THERE SHALL BE NO DISCHARGE OF FLOATING SOLIDS OR VISIBLE FOAM IN OTHER THAN TRACE AMOUNTS. | | | | | | |
| B. STANDARD CONDITIONS | | | | | | |
| IN ADDITION TO SPECIFIED CONDITIONS STATED HEREIN, THIS PERMIT IS SUBJECT TO THE ATTACHED <u>Parts I & III</u> STANDARD CONDITIONS DATED <u>October 1, 1980 and August 15, 1994</u> , AND HEREBY INCORPORATED AS THOUGH FULLY SET FORTH HEREIN. | | | | | | |

MO 780-0010 (8/91)

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (continued)

- * - Monitoring and reporting requirement only.
- ** - This facility is required to meet a removal efficiency of 65% or more.
- *** - Sample once per quarter in the months of March, May, September and November.
- **** - pH is measured in pH units and is not to be averaged. The pH is limited to the range of 6.0-9.0 pH units.

Note 1 - a composite sample made up from a minimum of four(4) grab samples collected within a twenty four (24) hour period with a minimum of two (2) hours between each grab.

C. SPECIAL CONDITIONS

1. This permit may be reopened and modified, or alternatively revoked and reissued, to:
 - (a) Comply with any applicable effluent standard or limitation issued or approved under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a) (2) of the Clean Water Act, if the effluent standard or limitation so issued or approved:
 - (1) contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
 - (2) controls any pollutant not limited in the permit.
 - (b) Incorporate new or modified effluent limitations or other conditions, if the result of a waste load allocation study, toxicity test or other information indicates changes are necessary to assure compliance with Missouri's Water Quality Standards.
 - (c) Incorporate new or modified effluent limitations or other conditions if, as the result of a watershed analysis, a Total Maximum Daily Load (TMDL) limitation is developed for the receiving waters which are currently included in Missouri's list of waters of the state not fully achieving the state's water quality standards, also called the 303(d) list. The permit as modified or reissued under this paragraph shall also contain any other requirements of the Clean Water Act then applicable.
2. All outfalls must be clearly marked in the field.

C. SPECIAL CONDITIONS (continued)

3. Permittee will cease discharge by connection to areawide wastewater treatment system within 90 days of notice of its availability

4. Changes in Discharges of Toxic Substances

The Permittee shall notify the Director as soon as it knows or has reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels:"
- (1) One hundred micrograms per liter (100 µg/L)
 - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,5 dinitrophenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
 - (3) Five (5) times the maximum concentration value reported for the pollutant in the permit application;
 - (4) The level established in Part A of the permit by the Director.
- (b) That they have begun or expect to begin to use or manufacture as an intermediate or final product or byproduct any toxic pollutant, which was not reported in the permit application.
- (c) That the effluent limit established in part A of the permit will be exceeded.

5. Report as no-discharge when a discharge does not occur during the report period.

6. Water Quality Standards

- (a) Discharges to waters of the state shall not cause a violation of water quality standards rule under 10 CSR 20-7.031, including both specific and general criteria.
- (b) General Criteria. The following general water quality criteria shall be applicable to all waters of the state at all times including mixing zones. No water contaminant, by itself or in combination with other substances, shall prevent the waters of the state from meeting the following conditions:
- (1) Waters shall be free from substances in sufficient amounts to cause the formation of putrescent, unsightly or harmful bottom deposits or prevent full maintenance of beneficial uses;
 - (2) Waters shall be free from oil, scum and floating debris in sufficient amounts to be unsightly or prevent full maintenance of beneficial uses;
 - (3) Waters shall be free from substances in sufficient amounts to cause unsightly color or turbidity, offensive odor or prevent full maintenance of beneficial uses;
 - (4) Waters shall be free from substances or conditions in sufficient amounts to result in toxicity to human, animal or aquatic life;
 - (5) There shall be no significant human health hazard from incidental contact with the water;
 - (6) There shall be no acute toxicity to livestock or wildlife watering;
 - (7) Waters shall be free from physical, chemical or hydrologic changes that would impair the natural biological community;
 - (8) Waters shall be free from used tires, car bodies, appliances, demolition debris, used vehicles or equipment and solid waste as defined in Missouri's Solid Waste Law, section 260.200, RSMo, except as the use of such materials is specifically permitted pursuant to section 260.200-260.247.

7. Sludge and Biosolids Use For Domestic Wastewater Treatment Facilities

- (a) Permittee shall comply with the pollutant limitations, monitoring, reporting, and other requirements in accordance with the attached permit Standard Conditions.
- (b) If sludge is not removed by a contract hauler, permittee is authorized to land apply biosolids. Permit Standard Conditions, Part III shall apply to the land application of biosolids. Permittee shall notify the department at least 180 days prior to the planned removal of biosolids. The department may require submittal of a biosolids management plan for department review and approval as determined appropriate on a case-by-case basis.

Date of Fact Sheet: August 18, 2006

Date of Public Notice: September 15, 2006

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) PERMIT
FACT SHEET

This Fact Sheet explains the applicable regulations and rationale for development of this permit and the public participation process.

NPDES PERMIT NUMBER: MO-0109177

FACILITY NAME: Beauty View Acres

OWNER NAME: Beauty View Acres Sewer District

LOCATION: Gray Summit, MO

RECEIVING STREAM: Tributary to Labadie Creek

FACILITY CONTACT PERSON: Don Howard

TEL (636)451-3310

FACILITY DESCRIPTION AND RATIONALE

The current 3 cell wastewater treatment lagoon serving Beauty View Acres, was constructed in the early 90s using 40% construction grant funding (SG#309-92) and a Rural Sewer Grant (S-321-91). The design flow for this facility is 26,000 gpd with a Population Equivalent of 260. The average flow for the past two years, based on discharge monitoring reports, has been 6,000 gpd. There are 19 homes, one 2-family apartment and 21 trailers in this development.

A UAA(use attainability analysis) was conducted on the tributary to Labadie Creek in July of 2005. No WBCR was observed. The stream did not have enough depth to meet the WBCR use at 5 of 5 sites. The WBCR designation was removed. The ammonia limits proposed are the default numbers used, based on the close distance of the classified stream and the absence of a stream study showing degradation of ammonia.

This permit will be issued for a period of five years.

Lat/Lon +3830120/-09050201



Missouri Department of Natural Resources
 Water Protection Program
 Water Pollution Control Branch

NPDES Permits and Engineering Section

Water Quality Review Sheet Check List
 Lagoon Operating Permit Renewal

Facility Information

FACILITY NAME: Beautvy View Acres PERMIT #: MO-0109177

FACILITY TYPE: 3 cell facultative lagoon AGE: 16 years

Outfall Characteristics

| OUTFALL | DESIGN FLOW (MGD) | ACTUAL FLOW (MGD) | ACTUAL FLOW/DESIGN FLOW |
|---------|-------------------|-------------------|-------------------------|
| 001 | .026 | .006 | 0.23 % |

Effluent Characteristics

Biochemical Oxygen Demand (BOD₅) In Compliance Significant Noncompliance
 Total Suspended Solids (TSS) In Compliance Significant Noncompliance
 Percent Removal (>65%) BOD & TSS In Compliance Significant Noncompliance N/A

Effluent Limit/Monitoring Requirement Frequency at regulatory minimum: Yes No

Receiving Waterbody Information

WATERBODY NAME: Tributary to Labadie Creek CLASS: P
 WATERBODY NAME: CLASS:

Discharge to or within two (2) miles of a losing stream (10 CSR 20-7.031, Table J or as determined by GSRAD)

Discharge to or within two (2) miles of a classified waterbody designated for whole body contact recreation

Use Attainability Analysis Conducted

Stream Survey Conducted within the past five (5) years Observed water quality impacts

If the facility discharges to any of the waterbody types below, is within an area experiencing rapid development, or if a site-specific water quality impact study has been conducted, this form is not applicable.

Lake/Reservoir 303(d) Waterbody Metropolitan No-Discharge Stream

Outstanding National/State Resource Water and Drainages Thereto